



CITY OF MT. SHASTA

305 North Mt. Shasta Boulevard
Mt. Shasta, California 96067
(530) 926-7510 • Telephone
(530) 926-0339 • Fax

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

DRINKING WATER WARNING

The City of Mt. Shasta water is contaminated with *E. coli*

BOIL YOUR WATER BEFORE USING

E. coli bacteria were found in the City of Mt. Shasta drinking water supply on June 24, 2017.

Coliform bacteria were detected in a routine water sample on Friday, June 23rd. Four follow-up samples were taken at various sites throughout the water system including the spring source. The sample taken from the spring was positive for *E. coli* bacteria (1 per 100 ml.) The other samples were negative for *E. coli* bacteria. These bacteria can make you sick, and are a particular concern for people with weakened immune systems.

What should I do?

- **DO NOT DRINK THE WATER WITHOUT BOILING IT FIRST.** Bring all water to a boil, let it boil for one minute, and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes, and food preparation **until further notice**. Boiling kills bacteria and other organisms in the water.
- *Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems. The symptoms above are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.*
- People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from U.S. EPA's Safe Drinking Water Hotline at 1(800) 426-4791.

What happened? What is being done?

Bacterial contamination can occur when increased run-off enters the drinking water source (for example, following heavy rains). It can also happen due to a break in the distribution system (pipes) or a failure in the water treatment process.

The drinking water system has been chlorinated as a precautionary measure and follow up samples have been collected and will be analyzed over the next several days. We will inform you when tests show no bacteria and you no longer need to boil your water. We anticipate resolving the problem within 7-10 days.

For more information, please contact the City at 530-926-7526 or by email at rbryan@mtshastaca.gov.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by the City of Mt. Shasta

State Water System ID#: 4710008. Date distributed: June 25, 2017.